

**ORDINANCE 475**  
**AN ORDINANCE OF THE TOWN OF BAYFIELD COLORADO, AMENDING**  
**INFRASTRUCTURE DESIGN STANDARDS DOMESTIC WATER SYSTEM 3.2.7.C**

**WHEREAS**, Infrastructure Design Standards were adopted by Ordinance 408 on May 14, 2017; and

**WHEREAS**, the Board of Trustees determine it is necessary to modify certain portions of the Town's Infrastructure Design Standards regarding developer requirements for meters; and

**WHEREAS**, this Ordinance amends Infrastructure Design Standards Domestic Water System 3.2.7.C Meters only.

**BE IT ORDAINED BY THE BOARD OF TRUSTEES FOR THE TOWN OF BAYFIELD, COLORADO, THAT INFRASTRUCTURE DESIGN STANDARDS DOMESTIC WATER SYSTEM 3.2.7.C METERS SHALL BE AMENDED BY THE FOLLOWING:**

*Meters:* All connections to the Town water distribution system shall be metered with an appropriately sized meter in accordance with AWWA recommendations. The minimum residential meter shall be 5/8 X 3/4 inch and the minimum commercial meter shall be 1 inch. Where sidewalks are detached from the curb, the meter pit shall be installed 2 feet behind the curb. Where sidewalks are attached to the curb, the meter pit shall be installed 2 feet behind the sidewalk, except for commercial property where the sidewalk extends to the building, in which case the meter pit shall be installed 2 feet behind the curb. All meters shall be located in the Town of Bayfield ROW in an accessible location for reading and servicing. Meter pits shall be installed by developer to meet the above requirements. Meter pits shall be ford prefabricated plastic pit setter with threaded exterior connection or an approved equal.

Effective thirty (30) days after publish.


**ADOPTED AND ORDERED PUBLISHED THIS 19<sup>th</sup> DAY OF April 2022.**

**The Town of Bayfield, Colorado Acting through the Bayfield Waterworks Operation**

MAYOR:

  
\_\_\_\_\_  
Ashleigh Tarkington

ATTEST:

  
\_\_\_\_\_  
Kathleen S. Cathcart, Town Clerk